




MULTILINE

bright with light

Metro installation instruction

Without recessed housing



	2,5 Nm	5 Nm	5,5 Nm	6 Nm
M4	✓			
M5		✓		
M6			✓	
M8				✓

1. Loosen the screws in the cover bezel.
2. Remove the cover bezel.
3. Remove the glass.
4. Position the lamp in the lampholder.

Make sure that the gasket, the glass, the bezel and the inside of the luminaire are absolutely free of dust, sand and little rocks before proceeding with step 5!

5. Put some vaseline on the gasket and put the glass back on the luminaire.
6. Put the bezel back on the luminaire and tighten the screws in the bezel crosswise and uniformly with a strength as indicated in the schedule above.
7. Connect the cable of the luminaire to your connection box: brown=L, blue=N, yellow/green=earth. Make sure that the supply cable is not twisted.
8. Fill the spacing around the housing with a stabilizer.




Make sure that the electrical connection between the supply cable of the luminaire and the main supply cable is vacuum sealed. The outer protection mantles of both cables have to be vacuum sealed in a sealing box!



MULTILINE

bright with light

Recessed housing included



	2,5 Nm	5 Nm	5,5 Nm	6 Nm
M4	✓			
M5		✓		
M6			✓	
M8				✓

1. Loosen the screws in the cover bezel.
2. Place the suction cup on the glass and turn the luminaire until it blocks.
3. Lift the luminaire out of the recessed housing.
4. Install the recessed housing onto a concrete foundation, while taking the following conditions into account:
 - make a hole in the foundation within the diameter of the recessed housing for the drainage of the water.
 - allow for sufficient draining under the foundation, preferably with a layer of pebble stones.
 - the diameter of the foundation is at least 20 cm bigger than the diameter of the recessed housing.
 - the height of the foundation is at least 10 cm.
5. Fix the recessed housing onto the foundation. In case of an asymmetric luminaire, make sure that the recessed housing is fixed in such a way that you can turn the luminaire in the desired position.
6. Run the supply cable of the luminaire through the recessed housing towards your connection box.
7. Connect the cable of the luminaire to your connection box: brown=L, blue=N, yellow/green=earth. Make sure that the supply cable is not twisted.
8. Fill the space around the recessing housing with a stabilizer.
9. Loosen the nuts underneath the flange of the luminaire and remove the cover bezel.
10. Remove the glass.
11. Position the lamp in the lampholder.
Make sure that the gasket, the glass, the bezel and the inside of the luminaire are absolutely free of dust, sand and little rocks before proceeding with step 12!
12. Put some vasiline on the gasket and put the glass back onto the luminaire.
13. Put the bezel back onto the luminaire. Tighten the nuts underneath the flange of the luminaire crosswise and uniformly with a strength as indicated in the above schedule.
14. Put the luminaire back into the recessed housing.
15. Turn the luminaire inside the recessed housing until it blocks.
16. Tighten the screws in the cover bezel.



Make sure that the electrical connection between the supply cable of the luminaire and the main supply cable is vacuum sealed. The outer protection mantles of both cables have to be vacuum sealed in a sealing box!